

# IMPORTANT NEC RULES & TABLES BASED ON 2008

## **ARTICLE 90: INTRODUCTION TO THE NATIONAL ELECTRICAL CODE**

1. 90.1 Purpose of NEC
2. 90.2 Scope of NEC
3. 90.3 Code Arrangement
4. 90.4 Enforcement
5. 90.5 Mandatory Requirement and Explanatory Material
6. 90.7 Examination of Equipment For Product Safety

## **CHAPTER 1: GENERAL**

### Article 110 Requirements for Electrical Installations

7. 110.2 Approval of conductors and equipment
8. 110.3 Examination, Identification, installation and use of equipment
9. 110.14 Conductor termination and splicing
10. 110.15 High leg marking
11. 110.16 Flash protection
12. 110.26 Spaces about electrical equipment

## **CHAPTER 2: WIRING AND PROTECTION**

### ARTICLE 200 Use and identification of grounded conductor

13. 200.6 Neutral conductor identification
14. 200.7 Use of white or Gray color

### ARTICLE 210 Branch Circuits

15. 210.3 Branch circuit rating
16. 210.4 Multi wire branch circuit
17. 210.5 Identification for branch circuits
18. 210.8 GFCI protection
19. 210.11 Branch circuit requirements
20. 210.12 AFCI protection
21. 210.19 Conductor minimum ampacity and sizing
22. 210.20 Overcurrent protection
23. 210.21 Outlet device rating
24. 210.52 Dwelling unit receptacle requirements
25. 210.70 Lighting outlet requirements

### ARTICLE 225 Outside Branch Circuits and Feeders

26. 225.6 Conductor Sizing and Support
27. 225.16 Attachment to Buildings
28. 225.17 Mast as Support
29. 225.18 Clearance for Overhead Conductors
30. 225.31 Disconnecting Means
31. 225.32 Disconnect Location
32. 225.36 suitable for Service Disconnect

ARTICLE 230 Services

- 33. 230.2 Number of Services
- 34. 230.6 Conductors Considered Outside
- 35. 230.7 Other Conductors in Raceway or Cable
- 36. 230.24 Clearance
- 37. 230.70 General
- 38. 230.71 Maximum Number of Disconnects
- 39. 230.72 Grouping of Disconnects

ARTICLE 240 Overcurrent Protection

- 40. 240.1 Scope
- 41. 240.2 Definitions
- 42. 240.4 Protection of Conductors
- 43. 240.6 Standard Size OCPD
- 44. 240.21 Location in Circuit

ARTICLE 250 Grounding & Bonding

- 45. 250.4 General Requirements for Grounding & Bonding
- 46. 250.6 Objectionable Current Flow
- 47. 250.8 Connection of Grounding and Bonding Equipment
- 48. 250.20 Grounding of A/C System
- 49. 250.24 Grounding Service A/C System
- 50. 250.28 Main Bonding and System Bonding Jumper
- 51. 250.30 Grounding Separately Derived System
- 52. 250.32 Building or Structure Supplied by a Feeder or Branch Circuit
- 53. 250.35 Permanently Installed Generators
- 54. 250.50 Grounding Electrode System
- 55. 250.52 Grounding Electrode
- 56. 250.53 Grounding Electrode System Installation
- 57. 250.54 Auxiliary Grounding Electrode
- 58. 250.56 Resistance of Electrode
- 59. 250.62 Grounding Electrode Material
- 60. 250.66 Size of Grounding Electrode
- 61. 250.68 GE Conductor and Bonding Jumper Connection
- 62. 250.70 Methods of Connection to Electrode
- 63. 250.86 Enclosures and Raceways
- 64. 250.92 Service Raceways and Enclosures
- 65. 250.94 Bonding for Other Systems (Intersystem)
- 66. 250.97 Bonding for 277-480 Volts
- 67. 250.102 Equipment Bonding Jumper
- 68. 250.104 Bonding of Piping Systems and Exposed Structure Steel
- 69. 250.112 Fastened in Place or Connected by Permanent wiring
- 70. 250.118 Types of Equipment grounding Conductor
- 71. 250.119 Identification of Equipment Grounding Conductor
- 72. 250.122 Size of Equipment Grounding Conductor
- 73. 250.130 EGC Connection
- 74. 250.132 Short Section of Raceway
- 75. 250.140 Frames of Ranges and Clothes Dryers
- 76. 250.142 Use of Grounded Circuit Conductors for Grounding Equipment
- 77. 250.146 Connection Receptacle Grounding Terminal to Box
- 78. 250.148 Continuity and Attachment of EGC in Box

## **CHAPTER 3: WIRING METHODS AND MATERIAL**

### ARTICLE 300 Wiring Methods

- 79. 300.3 Conductors
- 80. 300.4 Protection Against Physical Damage
- 81. 300.5 Underground Installation
- 82. 300.10 Electrical Continuity of Metal Raceways & Enclosures
- 83. 300.11 Securing and Supporting
- 84. 300.12 Mechanical Continuity
- 85. 300.13 Pig Tails Mechanical and Electrical continuity of Conductors
- 86. 300.14 Length of Free Conductors
- 87. 300.15 Required Boxes and Conduit Bodies
- 88. 300.20 Induced Current in Ferrous Metal Enclosures and Conduits
- 89. 300.21 Spread of Fire or Products of Combustion
- 90. 300.22 Wiring in Ducts and Plenums and other locations

### ARTICLE 310 Conductors for General Wiring

- 91. 310.4 Conductors in Parallel
- 92. 310.13 Conductor Construction and Application
- 93. 310.15 Conductor Ampacity (Table 310.16)

### ARTICLE 312 Cabinets, Cutout Boxes and Meter Socket Enclosures

- 94. 312.3 Position in Wall
- 95. 312.4 Repairing Non-Combustible Surface
- 96. 312.5 Cabinets, Cutout Boxes and Meter Socket Enclosures
- 97. 312.8 Enclosures for Switches and Overcurrent Devices

### ARTICLE 314 Outlet, Device, Pull and Junction Box, Conduit Bodies and Handhole Enclosures

- 98. 314.16 Installation of number 6AWG and Smaller Conductor
- 99. 314.23 Support of Boxes and Conduit Bodies
- 100. 314.28 Conduit bodies and Boxes for larger than 4AWG conductor
- 101. 314.29 Wiring in Enclosures to Be Accessible

### ARTICLE 320 Armored Cable (Type AC)

- 102. 320.10 Uses Permitted
- 103. 320.15 Exposed Work
- 104. 320.17 Through or Parallel to Framing
- 105. 320.30 Securing and Supporting
- 106. 320.40 Boxes and Fitting For AC Cable
- 107. 320.108 Equipment Grounding Conductor

### ARTICLE 330 Metal Clad Cable (Type MC)

- 108. 330.10 Uses Permitted
- 109. 330.12 Uses Not Permitted

### ARTICLE 334 Nonmetallic Sheathed Cable (Romex)

- 110. 334.10 Uses Permitted
- 111. 334.12 Uses Not Permitted
- 112. 334.15 Exposed Work

### Article 344 Rigid Metal Conduit

- 113. 344. 10 Uses permitted
- 114. 344.12. Uses not permitted

### ARTICLE 358 Electrical Metallic Tubing

- 115. 358.10 Uses Permitted
- 116. 358.12 Uses Not Permitted

**CHAPTER 4: EQUIPMENT FOR GENERAL USE**

ARTICLE 404 Switches

- 117. 404.3 Enclosures
- 118. 404.4 Damp or Wet Location
- 119. 404.7 Indicating
- 120. 404.8 Accessibility and Grouping
- 121. 404.9 Switch Cover Plates

ARTICLE 406 Receptacles, Cord connector and Attachment Plugs

- 122. 406.4 Receptacle Mounting
- 123. 406.8 Receptacles in Damp and Wet Locations
- 124. 406.11 Tamper Resistance Receptacles

ARTICLE 408 Switch Boards and Panel Boards

- 125. 408.3 Support and arrangement of Busbars and Conductors
- 126. 408.4 Circuit Directory & Identification

ARTICLE 410 Luminaires, Lamp Holders and Lamps

- 127. 410.10 Luminaires in Specific Locations
- 128. 410.16 Luminaires in Clothes Closets

ARTICLE 422 Appliances

- 129. 422.11 Overcurrent Protection
- 130. 422.13 Storage Type Water Heaters
- 131. 422.16 Flexible Cords
- 132. 422.33 Disconnecting of Cord & Plug Connected Appliances

ARTICLE 430 Motors, Motor Circuits and Controllers

- 133. 430.6 Ampacity and Motor Rating Determination
- 134. 430.22 Single Motor Conductor Sizing
- 135. 430.31 Motor and Branch Circuit Over Load Protection
- 136. 430.32 Over Load for Continuous Motors
- 137. 430.52 Branch Circuit, Short Circuit and Ground Fault Protection
- 138. 430.75 Motor Control Disconnect
- 139. 430.102 Required Disconnect and Location

ARTICLE 440 Air Conditioning and Refrigeration

- 140. 440.14 Required Disconnect and Location
- 141. 440.22 OCPD Size for Ground Fault and Short Circuit
- 142. 440.32 Branch Circuit sizing for Single Motor Compressor

ARTICLE 450 Transformers

- 143. 450.3 Overcurrent Protection

## TABLES AND ANNEXES

110.20	Enclosure selection
110.26(a)(1)	Working spaces in front of electrical equipment
210.21.(b)(2)	Maximum cord and plug connected load to receptacles
210.21(b)(3)	Receptacles rating for various size circuit breakers
210.24	Summary of branch circuit requirements
220.12	General Lighting loads by occupancy
220.42	Lighting load demand factor
220.54	Demand factor for <b>Household</b> dryers
220.55	Demand factor for <b>Household</b> electric ranges
250.66	Sizing GEC based on the largest service entrance conductors
250.122	Sizing of EGC based on the overcurrent protection device
300.5	Minimum cover for burial depth
310.13(a)	Conductor application and insulation
310.15(b)(2)(a)	Adjustment factor for more than 3 current carrying conductors in a raceway or cable
310.15(b)(2)(c)	Ambient temperature adjustment for conduit exposed to sunlight on or above the roof
310.15(b)(6)	DWELLING ONLY permitted reduction in service & feeder conductor
310.16	Conductor ampacity based on 3 current carrying conductor and 86F
314.16 (a)	Metal box fill volume
314.16(b)	Volume required per conductor
400.4	Flexible cords and cables
430.52	Maximum rating or setting of motor branch circuit short circuit and ground fault protective device
430.248	FLA for single phase A/C motor (used for BR sizing)
430.250	FLA for 3 phase motors
	<b>CHAPTER 9</b>
Table 1	Percent of cross sectional of conduit and tubing. Notes 1-9 that apply to table 1
Table 4	Conduit and tubing dimensions and percentage fill
Table 5	Dimensions of insulated conductor (including the insulation)
Table 8	<b>BARE</b> Conductor properties for (size, stranding, dimensions, DC resistance)
	<b>ANNEX "C"</b>
	Conduit and tubing fill tables with the same size conductors.
	<b>ANNEX "D"</b>
	Examples of "Load Calculation"

[WWW.LEARNNEC.NET](http://WWW.LEARNNEC.NET)

[WWW.ELECTRICIANCERTIFICATIONCLASS.NET](http://WWW.ELECTRICIANCERTIFICATIONCLASS.NET)

408-866-7890